



Product Service

CERTIFICATE

No. Z2 105870 0004 Rev. 00

Holder of Certificate: **Changzhou EGing Photovoltaic Technology Co., Ltd.**

No.18 Jinwu Road, Yaotang Town
Jintan District
213213 Changzhou City, Jiangsu
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062312702-00

Valid until: 2028-06-06

Date, 2023-07-07

(Zhulin Zhang)



CERTIFICATE

No. Z2 105870 0004 Rev. 00

Model(s):

EG-xxxM84-HE/BF-DG,xxx=500 to 535, in steps of 5,
EG-xxxM78-HE/BF-DG,xxx=465 to 495, in steps of 5,
EG-xxxM72-HE/BF-DG,xxx=425 to 460, in steps of 5,
EG-xxxM60-HE/BF-DG,xxx=350 to 380, in steps of 5,
EG-xxxM72-HL/BF-DG,xxx=530 to 550, in steps of 5,
EG-xxxM60-HL/BF-DG,xxx=440 to 455, in steps of 5,
EG-xxxM54-HL/BF-DG,xxx=395 to 410, in steps of 5,
EG-xxxM66-HU/BF-DG,xxx=640 to 675, in steps of 5,
EG-xxxM60-HU/BF-DG,xxx=580 to 605, in steps of 5,
EG-xxxM54-HU/BF-DG,xxx=520 to 545, in steps of 5,
EG-xxxNT72-HL/BF-DG,xxx=550 to 570, in steps of 5,
EG-xxxNT60-HL/BF-DG,xxx=460 to 475, in steps of 5,
EG-xxxNT54-HL/BF-DG,xxx=415 to 425, in steps of 5,
EG-xxxNT66-HU/BF-DG,xxx=660 to 695, in steps of 5,
EG-xxxNT60-HU/BF-DG,xxx=600 to 630, in steps of 5,
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed double glass with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016