



Product Service

Attestation of Conformity

No. N8A 105870 0007 Rev. 00

Holder of Attestation: **Changzhou EGing Photovoltaic Technology Co., Ltd.**

No.18 Jinwu Road, Yaotang Town
Jintan District
213213 Changzhou City, Jiangsu
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062312701-00

Date, 2023-07-07

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

Attestation of Conformity

No. N8A 105870 0007 Rev. 00

Model(s):

EG-xxxM84-HEV, xxx=500 to 535, in steps of 5,
 EG-xxxM78-HEV, xxx=465 to 495, in steps of 5,
 EG-xxxM72-HEV, xxx=425 to 460, in steps of 5,
 EG-xxxM60-HEV, xxx=350 to 380, in steps of 5,
 EG-xxxM72-HLV, xxx=530 to 555, in steps of 5,
 EG-xxxM60-HLV, xxx=440 to 460, in steps of 5,
 EG-xxxM54-HLV, xxx=395 to 415, in steps of 5,
 EG-xxxM66-HUV, xxx=640 to 670, in steps of 5,
 EG-xxxM60-HUV, xxx=580 to 610, in steps of 5,
 EG-xxxM54-HUV, xxx=520 to 550, in steps of 5,
 EG-xxxM50-TUV, xxx=480 to 510, in steps of 5,
 EG-xxxM40-TUV, xxx=385 to 405, in steps of 5,
 EG-xxxNT78-HLV, xxx=605 to 625, in steps of 5,
 EG-xxxNT72-HLV, xxx=555 to 585, in steps of 5,
 EG-xxxNT60-HLV, xxx=460 to 495, in steps of 5,
 EG-xxxNT54-HLV, xxx=415 to 450, in steps of 5,
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

